

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Test disconnect terminal blocks for copper conductors

Name and address of the applicant

Weidmüller Interface GmbH & Co. KG
Klingenbergstrasse 16 / 26, 32758 Detmold
Germany

Name and address of the manufacturer

Weidmüller Interface GmbH & Co. KG
Klingenbergstrasse 16 / 26, 32758 Detmold
Germany

Name and address of the factory

*Note: When more than one factory, please report on page 2*Weidmüller Interface GmbH & Co. KG
Klingenbergstrasse 16 / 26, 32758 Detmold
Germany☒ Additional information on page 2

Ratings and principal characteristics

Rated cross-section 6 mm²
ATTB 6: Ui 500 V, Uimp 6 kV, Ith 30 AATTB 6 PG VT: basic terminal block: Ui 500 V, Uimp 6 kV, Ith 30 A
(used with plug type APG 6/1 up to and including APG 6/10: Ui 500 V,
Uimp 6 kV, Ith 30 A)ATTB 6 PG CT: basic terminal block: Ui 500 V, Uimp 6 kV, Ith 30 A
(used with plug type APG 6/2 MBB or APG 6/3. MBB: Ui 320 V,
Uimp 4 kV, Ith 30 A)

Trademark (if any)

Weidmüller

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

ATTB 6, ATTB 6 PG CT and ATT6 PG VT

Additional information (if necessary may also be reported on page 2)

This CB Test Certificate replaces CB Test Certificate NL-73754 issued on 2021-07-01, due to the fact that types ATT 6 PG CT and ATTB 6 PG VT are added. The terminal blocks are tested according to IEC 60947-7-1 Annex D: Additional requirements for test disconnect terminal blocks.

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-7-1:2009

As shown in the Test Report Ref. No. which forms part of this Certificate

2262100.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem
Netherlands

Date: 2022-06-13

Signature: H.R.M. Barends

A handwritten signature in blue ink, appearing to read 'H. Barends', written over the printed name.

Additional factory

Weidmüller Interface Romania S. R. L.
Strada 66, 437345 Tautii Magheraus
Romania

EWE s.r.o.
Trebovska 570, 562 03 Usti Nad Orlici
Czech Republic

Weidmüller Interface (Suzhou) Co. Ltd.
No. 58 Shilin Road, 215151 Suzhou
China

Weidmuller Lanskroun, s.r.o.
Dobrovskeho 1115, 56301 Lanskroun
Czech Republic

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem
Netherlands



DEKRA

Date: 2022-06-13

Signature: H.R.M. Barends