

# **Certificate of Compliance**

Certificate: 70153051 Master Contract: 200039

**Project:** 70153051 **Date Issued:** 2017-09-27

Issued to: Weidmüller Interface GmbH & Co. KG

Klingenbergstrasse 16

32758 Detmold GERMANY

Attention: Mr. Jochen Reese

The products listed below are eligible to bear the CSA Mark shown



Issued by: Michael Janker Michael Janker

#### **PRODUCTS**

CLASS 6228 01 – WIRE CONNECTING DEVICES – Terminal Assemblies

Terminal block series with spring forces, for use with solid and stranded insulated copper conductors, Cat. No. **BHF**, followed by 5.00, followed by /02, /03 or /04, followed by /180 or blank, followed by LH or blank, followed by XX/XX. Denoting color combination.

Component Terminal Block pin header series, Cat. No. **SHL**, followed by SMT, followed by 5.00, followed by /02, /03 or /04, followed by GR or GL followed by 1.5..5.9.

				Wire		Strip		
	Voltage		Current	range	Torque	length		
Catalogue #	[V]	Group	[A]	[AWG]	[Nm]	[mm]	Remarks	
SHL-SMT	300	B, D	9				Cu,	
5.0	50	C	9				Factory wiring only	
BHF 5.0	300	B, D	10	20-14		10	Solid/Stranded, Cu,	
	50, 150	C	10	20-14		10	Factory and field wiring only	

DQD 507 Rev. 2016-02-18 Page 1



Certificate: 70153051 Master Contract: 200039

**Project:** 70153051 **Date Issued:** 2017-09-27

#### Notes:

1. Certified for use in other equipment where the acceptability of the combination is to be determined by CSA Group or another NRTL.

- 2. Terminal blocks specified for Group Designation D shall be used only in or with industrial control equipment where the load on any single circuit of the terminal block does not exceed 15 A at 51-150 V, 10 A at 151-300 V, 5 A at 301-600 V, or the max current rating, whichever is less.
- 3. The spacing, specified under construction details, shall be maintained between uninsulated live parts of opposite polarity; and between and uninsulated live part and a grounded part including any mounting surface or exposed metal part.

#### **APPLICABLE REQUIREMENTS**

CSA C22.2 No. 0 - 10 - General Requirements Canadian Electrical Code, Part II

CSA C22.2 No. 158 - 10 - Terminal Blocks

DQD 507 Rev. 2016-02-18 Page 2



Certificate: 70153051 Master Contract: 200039

**Project:** 70153051 **Date Issued:** 2017-09-27

#### **Conditions of Acceptability:**

# 1. Insulation materials

The following materials are used, see description for details:

	-	_	UL file		Thickness	Flame	RTI °C]
id	Type designation	Manufacturer	no.	CTI [V]	[mm]	Class	Elec/Str
1	Wellamid 6600-PA66-	CP-Polymer-Technik	E63957	600 and	0.4	V-2	130/120
	HWV0CP			greater			
2	6140L	CELANESE	E344082	175	0.4	V-0	130/130
		INTERNATIONAL		through			
		CORP		249			
3	A63 V0GV	Nilit Plastics Europe	E86034	600 and	0.75	V-0	130/130
		GmbH & Co KG		greater			
4	Grilon XE5017	EMS-CHEMIE AG	E53898	600 and	0.8	V-0	120/140
				greater			

2.

These terminal blocks consist of a construction that exposes the live screw underneath the terminal block. Spacings were not measured from the bottom of the screw to the terminal block-mounting surface, since the terminal block is intended to be mounted to a circuit board (utilizes solder post). Spacing measurements are recommended as part of the end product investigation, if the terminal is mounted to a surface other than a printed circuit or if printed circuit board traces are routed under the terminal block.

- For a 2 piece terminal block, a header having a voltage rating less than the detachable terminal block, may be used at the higher voltage when subjected to a suitable evaluation for the higher voltage in the end-use investigation.
- 4. Terminal block type BHF 5.00 and Header SHL SMT 5.00 are intended to be used with the housing types CH20M12, CH20M17, CH20M22 and CH20M45 as a part of a system. The housings CH20M12, CH20M17, CH20M22 and CH20M45 are intended by the manufacturer to be used for UL508 applications. The plastic material fulfills the requirements for direct support of uninsulated live parts according table 15.1 of the standard UL 508 in the areas capped by the intended PWB-contour and has a minimum thickness of 1.2 mm in these areas with a related RTI Elec of 120. The suitability of the housings shall be judged in the end-use application.

DOD 507 Rev. 2016-02-18 Page 3



## Supplement to Certificate of Compliance

Certificate: 70153051 Master Contract: 200039

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

### **Product Certification History**

Project	Date	Description
70153051	2017-09-27	Original Certification of springe force terminal blocks BHF 5.00 (acceptance of test data, without testing). To requirements of CSA No. 158-10, classes 6228-01.

DQD 507 Rev. 2016-02-18 Page 1